

Head Office

Unit 12, 8 Leighton Place
Hornsby
NSW, 2077
Australia

Firefly Office

P.O BOX 52
Laidley
QLD, 4341
Australia

Contact details

Phone: (07) 5411 4209
Mobile: 0400 966 899
Email: trevor@tbafirefly.com.au

MATERIAL DESCRIPTION

Firefly retro-fit fire collars are made from steel and high pressure graphite intumescent.

CERTIFICATION

Tested to AS1530.4-2005 and
Assessed in accordance with
AS4072.1-2005
EWFA 34088500

SIZE

40mm, 50mm, 65mm, 80mm, 100mm,
150mm and 160mm

FRL-/120/120

APPLICATIONS

Firefly RF Fire Collars are used to close off PVC pipes, HDPE pipes, beer lines, aircon lagged pipes and cables where they penetrate our Firefly Intubatt Systems in both vertical and horizontal applications. Once the first layer of Intubatt is installed, our small fixing plates are pronged into the Intubatt, then the second layer of Intubatt is installed, sandwiching the plates. Our RF fire collars are then screw fixed to the Intubatt using 75mm drywall screws picking up the fixing plates within. Our fixing plates are pre-punched at the corners so they can be bent 90 degrees using plyers to form pointy prongs.

FIREFLY RF FIRE COLLARS



Firefly RF Fire Collars



Firefly Pronged Fixing Plates



Non Fireside Prior to the start of one of our Fire Tests