



Testing Authority  
 CSIRO Infrastructure Technologies  
 14 Julius Avenue, North Ryde NSW 2113  
 PO Box 310, North Ryde NSW 1670, Australia  
 T (02) 9490 5444 • ABN 41 687 119 230

# Certificate of Assessment

Certificate Of Assessment Number	Certificate Issue Date	Certificate Validity Date	Page
COA 3228A	31/01/2017	31/01/2022	1 of 1

Referenced Assessment	Test Standard	Proprietary Name(s)	Report Sponsor
RIR FCO-3228A	AS1530.4-2014 and AS4072.1-2005	TBA Firefly FR Block	TBA Textiles Pty Ltd Unit 12, 8 Leighton Place Hornsby NSW 2077

### Introduction

The Element of construction below was assessed by this laboratory on behalf of the report sponsor in accordance with the stated test standard and achieved the results stated below. Refer to the referenced assessment report for a full description of the assessed construction and performance claims.

### Product Details & Performance Outcome(s)

Product Description & Installation	FRL
<ul style="list-style-type: none"> <li>The TBA Firefly FR Block may be fitted to various substrates including Speedpanel, Fire Grade Plasterboard lined wall, INEX Wallboard lined wall, TBA Intubatt Penetration Seal, Solid and hollow masonry, Brickworks Prontopanel, Hebel Powerpanel.</li> <li>The TBA Firefly FR Block will accept various, cables, plastic and metal pipes.</li> <li>Refer to the referenced assessment report for a full description of the assessed construction and performance claims.</li> </ul>	-/60/60

### Limitations

- This Certificate provides summary information only and does not comply the regulatory requirements for evidence of compliance.
- The referenced assessment report provides full details of the tested system, the results, observations, conclusions limitations and validity of test. This relevant assessment report should be viewed for the purposes for evidence of compliance.
- The test results relate to only the behaviour of the specimen under the particular conditions of test; they are not intended to provide a full assessment of fire hazard under all fire conditions.

Author	Reviewed By	Authorised
Keith Nicholls 	Brett Roddy 	Brett Roddy 
31/1/2017	31/1/2017	31/1/2017