



Testing. Advising. Assuring.

<b>EWFA CERTIFICATE OF ASSESSMENT</b>	<b>CERTIFICATE No : SFC 23990-04</b>	<b>Page 1 of 1</b>
---------------------------------------	--------------------------------------	--------------------

Report Sponsor	Certificate Issue Date	Product Name
TBA Textiles P/L Unit 12, 8 Leighton Place Hornsby, NSW 2077, Australia	18/03/15	<b>TBA BAL-FZ Roofing System</b>

Assessment Report Reference	Test Methods	Report Issue Date	Report Validity Date
EWFA 23990-03	AS1530.8.2-2007	6/2/14	28/2/19

Introduction
--------------



The element of construction described below was assessed by this laboratory on behalf of the report sponsor in accordance with the stated test standard and achieved the results stated below. Refer to the referenced test report(s) for more information.

Assessed Roof System Description and Performance
--

Roof System Description	BAL
<p>The sheet metal sheet and tile roof system protected with TBA Firefly 60 Plus and Firefly Intubatt.</p> <p>The Firefly Plus 60 blanket lining consists of woven e-glass, 60 micron foil and e-glass wadding and is installed over the roof framing.</p> <p>The Firefly Intubatt consists of mineral fibre boards with a 1mm thick Firefly Intucoat mastic coat on the exposed side and is installed to the eaves, fascia and nominally 150mm up the raked face of the roof, directly on top of the Firefly Plus 60.</p> <p>Refer the referenced report for a complete description of the assessed construction.</p>	<b>BAL-FZ</b>

Conditions/Validity
---------------------

- THIS CERTIFICATE IS PROVIDED FOR GENERAL INFORMATION ONLY AND DOES NOT COMPLY WITH THE REGULATORY REQUIREMENTS FOR EVIDENCE OF COMPLIANCE.
- Reference should be made to the relevant test report or regulatory information report to determine the applicability of the test result to a proposed installation. Full details of the constructions and justification for the conclusions given, along with the validity statements, are given in the assessment reports.
- The results of these fire tests may be used to assess fire hazard, but it should be recognized that a single test method will not provide a full assessment of fire hazard under all conditions.

<b>TESTING AUTHORITY</b>	Exova Warringtonfire Aus Pty Ltd	
<b>Address</b>	Suite 2002a, Level 20, 44 Market Street, Sydney NSW 2000, Australia	
<b>Phone / Fax</b>	+61 (0)2 8270 7600 / +61 (0)2 9299 6076	
<b>ABN</b>	81 050 241 524	
<b>Email / Home Page</b>	<a href="http://www.exova.com">www.exova.com</a>	
<b>Authorisation</b>	Prepared By:  D. Nicholson	Reviewed By:  K. G. Nicholls