

## WFA CERTIFICATE OF ASSESSMENT

Certificate No: SFC23990-05

Report Sponsor	Certificate Issue Date	Product Name
TBA Textiles P/L Unit 12, 8 Leighton Place Hornsby, NSW 2077, Australia	20 March 2019	TBA BAL-FZ Roofing System

Referenced Assessment report	Test methods	Report issue date	Report validity date
WFA 23990-05	AS 1530.8.2:2018	20 March 2019	31 March 2024



## Introduction

The element of construction described below was assessed by this laboratory on behalf of the test sponsor in accordance with the stated test standard and achieved the results stated below. Refer to the referenced Assessment Report(s) or Regulatory Information Report(s) for the complete description of the assessment construction.

Description of assessment product and performance	Assessment summary
<p>The sheet metal sheet and tile roof system protected with TBA Firefly 60 Plus and Firefly Intubatt.</p> <p>The Firefly Plus 60 blanket lining consists of woven e-glass, 60 micron foil and e-glass wadding and is installed over the roof framing.</p> <p>The Firefly Intubatt consists of mineral fibre boards with a 1mm thick Firefly Intucoat mastic coat on the exposed side and is installed to the eaves, fascia and nominally 150mm up the raked face of the roof, directly on top of the Firefly Plus 60.</p> <ul style="list-style-type: none"> <li>Refer the referenced report for a complete description of the assessed construction.</li> </ul>	<b>BAL-FZ</b>

## Conditions/ Validity

- This certificate is provided for general information only and does not comply with the regulatory requirements for evidence of compliance.
- Reference should be made to the relevant test report or regulatory information report to determine the applicability of the test result to a proposed installation. Full details of the constructions and justification for the conclusions given, along with the validity statements, are given in the assessment reports.
- The results of these fire tests may be used to assess fire hazard, but it should be recognized that a single test method will not provide a full assessment of fire hazard under all conditions.
- All work and services carried out by Warringtonfire Australia Pty Ltd ACN 050 241 524 are subject to, and conducted in accordance with, the standard terms and conditions of Warringtonfire Australia Pty Ltd, which are available at <https://www.element.com/terms/terms-and-conditions> or upon request.
- Exova Warringtonfire rebranded to Warringtonfire on 1 December 2018. Apart from the change to our brand name, no other changes have occurred. The introduction of our new brand name does not affect the validity of existing documents previously issued by Us.

<b>TESTING AUTHORITY</b>	Warringtonfire Aus Pty Ltd	
<b>Address</b>	2/409-411 Hammond Rd, Dandenong South VIC 3175	
<b>Phone / Fax</b>	(03) 9767 1000	
<b>ABN</b>	81 050 241 524	
<b>Authorisation</b>	Prepared By:  Rami Aldarwish	Reviewed By:  Omar Saad